

**Subject : Bacteriological Examination Report of Water Samples**

Circle **Karnal Circle**

Division **Karnal PHED No. 1**

Sub Division **Nilokheri PHESD**

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
<b>Memo No :- 2388, Date :- 13/05/2024</b>				
1	<b>Sample ID:-KNL/01961/5/2024 /Sender : Nilokheri PHESD ,Location : , G s. s.s code 1949 PADANA taroari, Analysis Start/End Date: 08/05/2024 / 10/05/2024, GPS Coordinates: 29.816242 /76.9558</b>			
	Total Coliform per 100 ml	150	IS 15185:2016/ APHA 9221C; 2017	Not Potable
	E-Coli (MNP/100 ml.)	NIL	IS 15185:2016	Not Potable
2	<b>Sample ID:-KNL/01962/5/2024 /Sender : Nilokheri PHESD ,Location : , G.s.s.s code no 1949 padhna taroari, Analysis Start/End Date: 08/05/2024 / 10/05/2024, GPS Coordinates: 29.816242 /76.9558</b>			
	Total Coliform per 100 ml	0.0	IS 15185:2016/ APHA 9221C; 2017	Potable
<b>Abstract Report of Bacteriological Examination Report of Water Sample</b>				
<b>Total Sample</b>		<b>Potable</b>		<b>Not Potable</b>
2		1		1

\* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

\*\* MPN (Most Probable Number) Per 100 ML.

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in KARNAL lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.

Sample analyzed by: *Jaginder Singh*

*Amit Kumar*  
AMIT KUMAR, CHIEF CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
STATE WATER TESTING LABORATORY KARNAL  
email:-chiefchemist.br@phedharyana.gov.in